

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20210880  
Address: 2118 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Failed	Thursday, October 21, 2021

Corrective Action Required:

2	Miscellaneous Correction	Fire block dead space & chase dining room Tighten anchor bolts garage Fire block furr outs garage Furr out HVAC for insulation garage Truss lock screw garage T19 near porch Solid block sheathing break landing near plant shelf Replace basement landing subfloor Address double floor joist cut near radon basement Address floor joist cut above furnace Provide joist hangers Mitch against stairway basement Fire block chase and soffit near patio door Address bores in LVL above refrigerator Fire block chase in pantry Address stud packs used in place of SCH 40 columns garage beam Replace LIB rear garage wall Fire block DWV bath 5 Provide solid security blocking patio door Replace stud bath 3 Snow blocking bed 3 Strap top plate bed 1 near shower Seal bad bore floor at tub Tran bath 2
---	--------------------------	---

Replace stud bath 4  
Nail studs at intersecting wall corners per code  
Provide 4 studs at GT bearing points bath 4 & bath 2

**Comments:**