

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204957
Address: 2041 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Thursday, October 21, 2021

Corrective Action Required:

1	Misc	-Final grade, sod, drainage extensions -All boxes in combustible surfaces to be flush face of surface per 3906.5 -Complete stair rail -Provide security screws per chapter 7 all locations
---	------	---

Comments: