

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211236
Address: 2163 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, October 21, 2021

Corrective Action Required:

1	Miscellaneous Correction	-Address single car bay to attached at top plates at return -Complete gas and fireplace installation and secure -Seal gaps between foundation wall and garage at ufer pocket and beam pocket -Repair damaged sheathing at sec -no pressure at gas gauge
---	--------------------------	---

Comments: