CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRPR20215525

Address: 664 SE BAYBERRY LN, Unit:105, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Electrical Service Inspection Robb Popp Failed Friday, October 22,

2021

Corrective Action Required:

1 Misc -Land conductors in disconnect and repair tapped conductors in other

services

Comments: