

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210948  
Address: 306 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Not Ready	Friday, October 22, 2021

Corrective Action Required:

1	Miscellaneous Correction	submit back flow certification - provide sod - -Moisture barrier on top of outside lighting fixtures and power meter. -label non-gfci outlets in garage. -install window above front door. - provide access panel for jet tub in master bedroom.
---	--------------------------	---

**Comments:**