

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210595
Address: 4409 SW ALABASTER CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, October 22, 2021

Corrective Action Required:

1	Misc	*obtain sprinkler permit * -Add splash blocks and extend sump pump discharge 36" from foundation -A/c breaker incorrect size -meter need be 14"-18" lid to lid -provide 6" between siding and grade
---	------	---

Comments: