

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211035
Address: 4412 SW ALABASTER CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, October 22, 2021

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">*obtain sprinkler permit*-open junction box front left of garage-exterior drainage 36" from foundation-gfcı for dishwasher-lockout for water heater breaker-secure A/c whip within 12" of disconnect-hand rail/guard rail at deck stairs bellow 34"
---	------	---

Comments: