

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210628
Address: 2106 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mark Harding	Not Ready	Friday, October 22, 2021

Corrective Action Required:

1	Misc	-City approved, stamped plans required on site for inspection, 2nd inspecction no truss plans. no rear door , missing 3 windows, no gravel entrance. Fire rated walls are not correct. soffits not blocked. this is the 8th house with the same issue.
---	------	--

Comments: