

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211111  
Address: 4413 SW ALABASTER CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Friday, October 22, 2021

Corrective Action Required:

1	Misc	*obtain sprinkler permit*
		-Outlet under kitchen counter top need gfci
		- add splash blocks and extend sump pump discharge 36" from foundation
		-seal garage lighting at siding
		-secure A/c whip within 12" of disconnect
		-provide 6" between siding and grade
		-all protruding trim to be flashed

**Comments:**