

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20214889
Address: 1215 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------|----------|--------------------------|
| Occupancy Inspection - Codes Commercial | Khanh Nguyen | Failed | Monday, October 25, 2021 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Fire approval required -Provide accessible restroom signage on latch side of door -For accessible restroom, install door knob compliant with ADA -Install open front toilet seat |
|---|------|--|

Comments: