

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200773
Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Planning	Hector Soto Jr.	Temporary C of O	Wednesday, October 13, 2021

Corrective Action Required:

1

LIGHT FIXTURES. Two wall-mounted light fixtures off the northeast and northwest building corners do not satisfy ordinance requirements for full cut-offs, nor do they match the cut sheets provided as part of the approved final development plan.

Comments: