

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202688
Address: 2341 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Tuesday, October 26, 2021

Corrective Action Required:

1	Miscellaneous Correction	- as grade plot plan - final grade, sod and splash blocks -Light fixture missing in upstairs hall bathroom -Set screw in back flow device in basement -Insulation in basement -1/2 " or equivalent through bolts on deck post for landing
---	--------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: