

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20203873
Address: 1916 SW RIVER RUN DR, LEES SUMMIT, MO 64082
Inspected On: Tuesday, October 26, 2021
Inspected By: Shawn Hoffman
Expiration Date: 11/12/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Temporary C of O	Tuesday, October 26, 2021

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -obtain an sprinkler permit and submit back flow certificate
- final grade and sod
-1/2" through bolts on deck 3 post
-attach a/c whip
- complete stucco on front on house |
|---|------|--|