



CITY OF LEE'S SUMMIT, MISSOURI

Support Services Division

115 SE 2nd Street, Lee's Summit, Missouri 64063

Phone # 960-7636 Fax # 960-7632

BACKFLOW PREVENTION ASSEMBLY TEST DATA AND MAINTENANCE REPORT

CUSTOMER Whataburger		ACCOUNT NUMBER	
SERVICE ADDRESS 1450 M.E. Douglas			
LOCATION OF DEVICE Ice Machine			
DATE OF TEST 9-30-21	TIME 11:00	<input checked="" type="checkbox"/> A.M. <input type="checkbox"/> P.M.	SUPPLY PRESSURE 75 LBS.
AIR GAP (2 X SUPPLY DIAM.) SUPPLY 1/2" IN. GAP 1/2" IN.		<input type="checkbox"/> PASS <input type="checkbox"/> FAIL	
TYPE OF ASSEMBLY PC	MANUFACTURER WAHs	MODEL L FOOT QT	SERIAL NUMBER 68343
HEIGHT OFF FLOOR 5 (IN./FT.)	PROTECTION FROM: FREEZING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO FLOODING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	COMMENTS: Ice Machine	
NEW INSTALLATION <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO			
INITIAL TEST		FINAL TEST AFTER REPAIR	
REDUCED PRESSURE PRINCIPAL ASSEMBLY:		REDUCED PRESSURE PRINCIPAL ASSEMBLY:	
RELIEF VALVE OPENED AT 2.0 *PSID (2 PSID or more)		RELIEF VALVE OPENED AT 2.0 PSID (2 PSID or more)	
2ND CHECK held backpressure		2ND CHECK held backpressure	
NO. 2 SHUT OFF VALVE leak tight		NO. 2 SHUT OFF VALVE leak tight	
1ST CHECK held in direction of flow 2.0 *PSID (5 PSID or more)		1ST CHECK held in direction of flow 2.0 PSID (5 PSID or more)	
DIFFERENCE (1st check - relief) 1.8 PSID (3 PSID or more)		DIFFERENCE (1st check - relief) 1.8 PSID (3 PSID or more)	
NOTE: Failure of any of the above items, requires repair.		*Pounds per Square Inch Differential	
DOUBLE CHECK VALVE ASSEMBLY:		DOUBLE CHECK VALVE ASSEMBLY:	
1ST CHECK held in direction of flow 2.0 PSID (1 PSID or more)		1ST CHECK held in direction of flow 2.0 PSID (1 PSID or more)	
2ND CHECK held backpressure		2ND CHECK held backpressure	
2ND CHECK held in direction of flow 1.8 PSID (1 PSID or more)		2ND CHECK held in direction of flow 1.8 PSID (1 PSID or more)	
NO. 2 SHUT OFF VALVE leak tight		NO. 2 SHUT OFF VALVE leak tight	
NOTE: Failure of any of the above items, requires repair.			
COMMERCIAL <input type="checkbox"/>	COMMENTS: Ice Machine		
FIRE LINE <input type="checkbox"/>			
IRRIGATION <input type="checkbox"/>			
REPAIR HISTORY			
THE ABOVE REPORT IS CERTIFIED TO BE TRUE, ACCURATE AND COMPLETE.			
TESTED BY (PRINT) Gordon Taylor (SIGNATURE) [Signature]		REPAIRED BY (PRINT) (SIGNATURE)	
COMPANY Taylor Mechanical		FINAL TEST BY (PRINT) (SIGNATURE)	
CERTIFICATION NUMBER 34-0248		OWNER OR OWNER'S REPRESENTATIVE	
		DATE 9-30-21	



CITY OF LEE'S SUMMIT, MISSOURI

Support Services Division

115 SE 2nd Street, Lee's Summit, Missouri 64063

Phone # 969-7636 Fax # 969-7632

BACKFLOW PREVENTION ASSEMBLY TEST DATA AND MAINTENANCE REPORT

CUSTOMER Whataburger		ACCOUNT NUMBER	
SERVICE ADDRESS 1450 N. E. Douglas			
LOCATION OF DEVICE At Coffee Maker			
DATE OF TEST 9-30-21	TIME 9:45	<input checked="" type="checkbox"/> A.M. <input type="checkbox"/> P.M.	SUPPLY PRESSURE 75 LBS.
AIR GAP (2 X SUPPLY DIAM.)		<input type="checkbox"/> PASS <input type="checkbox"/> FAIL	
SUPPLY 1/2" IN. GAP 1/2" IN.			
TYPE OF ASSEMBLY DC	MANUFACTURER Watts	MODEL LF007 BT	SERIAL NUMBER 09472
HEIGHT OFF FLOOR 4' (IN./FT.)	PROTECTION FROM: FREEZING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO FLOODING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		NEW INSTALLATION <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
INITIAL TEST		PASSED	FAILED
REDUCED PRESSURE PRINCIPAL ASSEMBLY:		<input type="checkbox"/>	<input type="checkbox"/>
RELIEF VALVE OPENED AT 2.0 *PSID (2 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held backpressure		<input type="checkbox"/>	<input type="checkbox"/>
NO. 2 SHUT OFF VALVE leak tight		<input type="checkbox"/>	<input type="checkbox"/>
1ST CHECK held in direction of flow 2.0 *PSID (5 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
DIFFERENCE (1st check - relief) 2.0 PSID (3 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
NOTE: Failure of any of the above items, requires repair.			
FINAL TEST AFTER REPAIR		PASSED	FAILED
REDUCED PRESSURE PRINCIPAL ASSEMBLY:		<input type="checkbox"/>	<input type="checkbox"/>
RELIEF VALVE OPENED AT 2.0 PSID (2 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held backpressure		<input type="checkbox"/>	<input type="checkbox"/>
NO. 2 SHUT OFF VALVE leak tight		<input type="checkbox"/>	<input type="checkbox"/>
1ST CHECK held in direction of flow 2.0 PSID (5 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
DIFFERENCE (1st check - relief) 2.0 PSID (3 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
*Pounds per Square Inch Differential			
INITIAL TEST		PASSED	FAILED
DOUBLE CHECK VALVE ASSEMBLY:		<input checked="" type="checkbox"/>	<input type="checkbox"/>
1ST CHECK held in direction of flow 2.0 PSID (1 PSID or more)		<input checked="" type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held backpressure		<input checked="" type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held in direction of flow 2.0 PSID (1 PSID or more)		<input checked="" type="checkbox"/>	<input type="checkbox"/>
NO. 2 SHUT OFF VALVE leak tight		<input checked="" type="checkbox"/>	<input type="checkbox"/>
NOTE: Failure of any of the above items, requires repair.			
FINAL TEST AFTER REPAIR		PASSED	FAILED
DOUBLE CHECK VALVE ASSEMBLY:		<input type="checkbox"/>	<input type="checkbox"/>
1ST CHECK held in direction of flow 2.0 PSID (1 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held backpressure		<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held in direction of flow 2.0 PSID (1 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
NO. 2 SHUT OFF VALVE leak tight		<input type="checkbox"/>	<input type="checkbox"/>
COMMENTS: Coffee maker			
COMMERCIAL <input type="checkbox"/>			
FIRE LINE <input type="checkbox"/>			
IRRIGATION <input type="checkbox"/>			
REPAIR HISTORY			
THE ABOVE REPORT IS CERTIFIED TO BE TRUE, ACCURATE AND COMPLETE.			
TESTED BY (PRINT) Gordon Taylor		REPAIRED BY (PRINT)	
(SIGNATURE) <i>[Signature]</i>		(SIGNATURE)	
COMPANY Taylor Mechanical		FINAL TEST BY (PRINT)	
		(SIGNATURE)	
CERTIFICATION NUMBER 34-0248		OWNER OR OWNER'S REPRESENTATIVE	
		DATE 9-30-21	



CITY OF LEE'S SUMMIT, MISSOURI

Support Services Division

115 SE 2nd Street, Lee's Summit, Missouri 64063

Phone # 969-7636 Fax # 969-7632

BACKFLOW PREVENTION ASSEMBLY TEST DATA AND MAINTENANCE REPORT

CUSTOMER Whataburger		ACCOUNT NUMBER	
SERVICE ADDRESS 1450 N. E. Douglas			
LOCATION OF DEVICE AT SHAKE MACHINE.			
DATE OF TEST 9-30-21	TIME 10:15	<input checked="" type="checkbox"/> A.M. <input type="checkbox"/> P.M.	SUPPLY PRESSURE 75 LBS.
AIR GAP (2 X SUPPLY DIAM.)		<input type="checkbox"/> PASS <input type="checkbox"/> FAIL	
SUPPLY 1/2" IN. GAP 1/2" IN.			
TYPE OF ASSEMBLY DC	MANUFACTURER WATTS	MODEL L FOOT QT	SERIAL NUMBER 68785
HEIGHT OFF FLOOR 4' (IN./FT.)	PROTECTION FROM: FREEZING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO FLOODING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		NEW INSTALLATION <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
INITIAL TEST		PASSED	FAILED
REDUCED PRESSURE PRINCIPAL ASSEMBLY:		<input type="checkbox"/>	<input type="checkbox"/>
RELIEF VALVE OPENED AT *PSID (2 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held backpressure		<input type="checkbox"/>	<input type="checkbox"/>
NO. 2 SHUT OFF VALVE leak tight		<input type="checkbox"/>	<input type="checkbox"/>
1ST CHECK held in direction of flow *PSID (5 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
DIFFERENCE (1st check - relief) PSID (3 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
NOTE: Failure of any of the above items, requires repair.			
FINAL TEST AFTER REPAIR		PASSED	FAILED
REDUCED PRESSURE PRINCIPAL ASSEMBLY:		<input type="checkbox"/>	<input type="checkbox"/>
RELIEF VALVE OPENED AT PSID (2 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held backpressure		<input type="checkbox"/>	<input type="checkbox"/>
NO. 2 SHUT OFF VALVE leak tight		<input type="checkbox"/>	<input type="checkbox"/>
1ST CHECK held in direction of flow PSID (5 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
DIFFERENCE (1st check - relief) PSID (3 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
*Pounds per Square Inch Differential			
INITIAL TEST		PASSED	FAILED
DOUBLE CHECK VALVE ASSEMBLY:		<input checked="" type="checkbox"/>	<input type="checkbox"/>
1ST CHECK held in direction of flow 1.8 PSID (1 PSID or more)		<input checked="" type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held backpressure		<input checked="" type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held in direction of flow 1.7 PSID (1 PSID or more)		<input checked="" type="checkbox"/>	<input type="checkbox"/>
NO. 2 SHUT OFF VALVE leak tight		<input checked="" type="checkbox"/>	<input type="checkbox"/>
NOTE: Failure of any of the above items, requires repair.			
FINAL TEST AFTER REPAIR		PASSED	FAILED
DOUBLE CHECK VALVE ASSEMBLY:		<input type="checkbox"/>	<input type="checkbox"/>
1ST CHECK held in direction of flow PSID (1 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held backpressure		<input type="checkbox"/>	<input type="checkbox"/>
2ND CHECK held in direction of flow PSID (1 PSID or more)		<input type="checkbox"/>	<input type="checkbox"/>
NO. 2 SHUT OFF VALVE leak tight		<input type="checkbox"/>	<input type="checkbox"/>
COMMENTS: SHAKE MACHINE.			
COMMERCIAL <input type="checkbox"/>			
FIRE LINE <input type="checkbox"/>			
IRRIGATION <input type="checkbox"/>			
REPAIR HISTORY			
THE ABOVE REPORT IS CERTIFIED TO BE TRUE, ACCURATE AND COMPLETE.			
TESTED BY (PRINT) Gordon Taylor		REPAIRED BY (PRINT) 	
(SIGNATURE) [Signature]		(SIGNATURE) 	
COMPANY Taylor Mechanical		FINAL TEST BY (PRINT) 	
(SIGNATURE) 		(SIGNATURE) 	
CERTIFICATION NUMBER 34-0248		OWNER OR OWNER'S REPRESENTATIVE	
		DATE 9-30-21	



CITY OF LEE'S SUMMIT, MISSOURI
Support Services Division
115 SE 2nd Street, Lee's Summit, Missouri 64063
Phone # 969-7636 Fax # 969-7632

BACKFLOW PREVENTION ASSEMBLY TEST DATA AND MAINTENANCE REPORT

CUSTOMER Whataburger		ACCOUNT NUMBER	
SERVICE ADDRESS 1450 N. E. Douglas			
LOCATION OF DEVICE Multi P/ex			
DATE OF TEST 9-30-21	TIME 10:30	<input checked="" type="checkbox"/> A.M. <input type="checkbox"/> P.M.	SUPPLY PRESSURE 75 LBS.
TYPE OF ASSEMBLY DC		MANUFACTURER WAH.	MODEL LF007 QT
HEIGHT OFF FLOOR 5 (IN./FT.)		PROTECTION FROM: FREEZING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO FLOODING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	AIR GAP (2 X SUPPLY DIAM.) SUPPLY 1/2 IN. GAP 1/2 IN.
COMMENTS:		SERIAL NUMBER 68906	
NEW INSTALLATION <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO			
INITIAL TEST		FINAL TEST AFTER REPAIR	
REDUCED PRESSURE PRINCIPAL ASSEMBLY:		REDUCED PRESSURE PRINCIPAL ASSEMBLY:	
RELIEF VALVE OPENED AT 22 *PSID (2 PSID or more)		RELIEF VALVE OPENED AT 22 PSID (2 PSID or more)	
2ND CHECK held backpressure		2ND CHECK held backpressure	
NO. 2 SHUT OFF VALVE leak tight		NO. 2 SHUT OFF VALVE leak tight	
1ST CHECK held in direction of flow 22 *PSID (5 PSID or more)		1ST CHECK held in direction of flow 22 PSID (5 PSID or more)	
DIFFERENCE (1st check - relief) 22 PSID (3 PSID or more)		DIFFERENCE (1st check - relief) 22 PSID (3 PSID or more)	
PASSED <input checked="" type="checkbox"/> FAILED <input type="checkbox"/>		PASSED <input checked="" type="checkbox"/> FAILED <input type="checkbox"/>	
NOTE: Failure of any of the above items, requires repair.		*Pounds per Square Inch Differential	
INITIAL TEST		FINAL TEST AFTER REPAIR	
DOUBLE CHECK VALVE ASSEMBLY:		DOUBLE CHECK VALVE ASSEMBLY:	
1ST CHECK held in direction of flow 22 PSID (1 PSID or more)		1ST CHECK held in direction of flow 22 PSID (1 PSID or more)	
2ND CHECK held backpressure		2ND CHECK held backpressure	
2ND CHECK held in direction of flow 22 PSID (1 PSID or more)		2ND CHECK held in direction of flow 22 PSID (1 PSID or more)	
NO. 2 SHUT OFF VALVE leak tight		NO. 2 SHUT OFF VALVE leak tight	
PASSED <input checked="" type="checkbox"/> FAILED <input type="checkbox"/>		PASSED <input checked="" type="checkbox"/> FAILED <input type="checkbox"/>	
NOTE: Failure of any of the above items, requires repair.			
COMMERCIAL <input type="checkbox"/>		COMMENTS: Multi-Plex unit	
FIRE LINE <input type="checkbox"/>			
IRRIGATION <input type="checkbox"/>			
REPAIR HISTORY			
THE ABOVE REPORT IS CERTIFIED TO BE TRUE, ACCURATE AND COMPLETE.			
TESTED BY (PRINT) Gordon Taylor		REPAIRED BY (PRINT) Gordon Taylor	
(SIGNATURE) <i>Gordon Taylor</i>		(SIGNATURE) <i>Gordon Taylor</i>	
COMPANY Taylor Mechanical		FINAL TEST BY (PRINT) Taylor Mechanical	
(SIGNATURE) <i>Taylor Mechanical</i>		(SIGNATURE) <i>Taylor Mechanical</i>	
CERTIFICATION NUMBER 34-0248		OWNER OR OWNER'S REPRESENTATIVE	
		DATE 9-30-21	

DISTRIBUTION: WHITE - WATER UTILITIES; YELLOW - OWNER OR TESTER



CITY OF LEE'S SUMMIT, MISSOURI
Support Services Division
115 SE 2nd Street, Lee's Summit, Missouri 64063
Phone # 969-7636 Fax # 969-7632

BACKFLOW PREVENTION ASSEMBLY TEST DATA AND MAINTENANCE REPORT

CUSTOMER Whataburger		ACCOUNT NUMBER	
SERVICE ADDRESS 1450 N. E. Douglas Street			
LOCATION OF DEVICE AT Tea Machine			
DATE OF TEST 9-30-20	TIME 10:00 <input checked="" type="checkbox"/> A.M. <input type="checkbox"/> P.M.	SUPPLY PRESSURE 15 LBS.	AIR GAP (2 X SUPPLY DIAM.) SUPPLY 1/2" IN. GAP 1/2" IN. <input type="checkbox"/> PASS <input type="checkbox"/> FAIL
TYPE OF ASSEMBLY DC	MANUFACTURER Watts	MODEL LF007 QT	SERIAL NUMBER 69794
HEIGHT OFF FLOOR 4 (IN./FT.)	PROTECTION FROM: FREEZING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO FLOODING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		COMMENTS: NEW INSTALLATION <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
INITIAL TEST		FINAL TEST AFTER REPAIR	
REDUCED PRESSURE PRINCIPAL ASSEMBLY:		REDUCED PRESSURE PRINCIPAL ASSEMBLY:	
RELIEF VALVE OPENED AT 2.2 *PSID (2 PSID or more)		RELIEF VALVE OPENED AT 2.2 PSID (2 PSID or more)	
2ND CHECK held backpressure		2ND CHECK held backpressure	
NO. 2 SHUT OFF VALVE leak tight		NO. 2 SHUT OFF VALVE leak tight	
1ST CHECK held in direction of flow 2.2 *PSID (5 PSID or more)		1ST CHECK held in direction of flow 2.2 PSID (5 PSID or more)	
DIFFERENCE (1st check - relief) 2.2 PSID (3 PSID or more)		DIFFERENCE (1st check - relief) 2.2 PSID (3 PSID or more)	
NOTE: Failure of any of the above items, requires repair.		*Pounds per Square Inch Differential	
INITIAL TEST		FINAL TEST AFTER REPAIR	
DOUBLE CHECK VALVE ASSEMBLY:		DOUBLE CHECK VALVE ASSEMBLY:	
1ST CHECK held in direction of flow 2.2 PSID (1 PSID or more)		1ST CHECK held in direction of flow 2.2 PSID (1 PSID or more)	
2ND CHECK held backpressure		2ND CHECK held backpressure	
2ND CHECK held in direction of flow 2.1 PSID (1 PSID or more)		2ND CHECK held in direction of flow 2.1 PSID (1 PSID or more)	
NO. 2 SHUT OFF VALVE leak tight		NO. 2 SHUT OFF VALVE leak tight	
NOTE: Failure of any of the above items, requires repair.			
COMMERCIAL <input type="checkbox"/>	COMMENTS: Tea machine		
FIRE LINE <input type="checkbox"/>			
IRRIGATION <input type="checkbox"/>			
REPAIR HISTORY			
THE ABOVE REPORT IS CERTIFIED TO BE TRUE, ACCURATE AND COMPLETE.			
TESTED BY (PRINT) Gordon Taylor (SIGNATURE) <i>[Signature]</i>		REPAIRED BY (PRINT) (SIGNATURE)	
COMPANY Taylor Mechanical		FINAL TEST BY (PRINT) (SIGNATURE)	
CERTIFICATION NUMBER 341-0248		OWNER OR OWNER'S REPRESENTATIVE	
		DATE 9-30-21	



CITY OF LEE'S SUMMIT, MISSOURI
Support Services Division
115 SE 2nd Street, Lee's Summit, Missouri 64063
Phone # 969-7636 Fax # 969-7632

BACKFLOW PREVENTION ASSEMBLY TEST DATA AND MAINTENANCE REPORT

CUSTOMER Whataburger		ACCOUNT NUMBER	
SERVICE ADDRESS 1450 N.E. Douglas Street			
LOCATION OF DEVICE Water Service Entry By Water Heater.			
DATE OF TEST 9-30-21	TIME 9:00 <input checked="" type="checkbox"/> A.M. <input type="checkbox"/> P.M.	SUPPLY PRESSURE 98 LBS.	AIR GAP (2 X SUPPLY DIAM.) SUPPLY 1 1/2 IN. GAP _____ IN. <input checked="" type="checkbox"/> PASS <input type="checkbox"/> FAIL
TYPE OF ASSEMBLY RPZ	MANUFACTURER WAHS.	MODEL LF009m2QT	SIZE 1 1/2"
HEIGHT OFF FLOOR 2 FT (IN./FT.)		PROTECTION FROM: FREEZING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO FLOODING <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	SERIAL NUMBER 096541
INITIAL TEST REDUCED PRESSURE PRINCIPAL ASSEMBLY:		FINAL TEST AFTER REPAIR REDUCED PRESSURE PRINCIPAL ASSEMBLY:	
RELIEF VALVE OPENED AT 4.9 *PSID (2 PSID or more)		RELIEF VALVE OPENED AT _____ PSID (2 PSID or more)	
2ND CHECK held backpressure		2ND CHECK held backpressure	
NO. 2 SHUT OFF VALVE leak tight		NO. 2 SHUT OFF VALVE leak tight	
1ST CHECK held in direction of flow 10.4 PSID (5 PSID or more)		1ST CHECK held in direction of flow _____ PSID (5 PSID or more)	
DIFFERENCE (1st check - relief) 5.5 PSID (3 PSID or more)		DIFFERENCE (1st check - relief) _____ PSID (3 PSID or more)	
NOTE: Failure of any of the above items, requires repair.		*Pounds per Square Inch Differential	
INITIAL TEST DOUBLE CHECK VALVE ASSEMBLY:		FINAL TEST AFTER REPAIR DOUBLE CHECK VALVE ASSEMBLY:	
1ST CHECK held in direction of flow _____ PSID (1 PSID or more)		1ST CHECK held in direction of flow _____ PSID (1 PSID or more)	
2ND CHECK held backpressure		2ND CHECK held backpressure	
2ND CHECK held in direction of flow _____ PSID (1 PSID or more)		2ND CHECK held in direction of flow _____ PSID (1 PSID or more)	
NO. 2 SHUT OFF VALVE leak tight		NO. 2 SHUT OFF VALVE leak tight	
NOTE: Failure of any of the above items, requires repair.			
COMMENTS: Pressure Regulator Installed After Back Flow.			
REPAIR HISTORY			
THE ABOVE REPORT IS CERTIFIED TO BE TRUE, ACCURATE AND COMPLETE.			
TESTED BY (PRINT) Gordon Taylor		REPAIRED BY (PRINT) _____	
(SIGNATURE) [Signature]		(SIGNATURE) _____	
COMPANY Taylor Mechanical		FINAL TEST BY (PRINT) _____	
CERTIFICATION NUMBER 34-0248		(SIGNATURE) _____	
OWNER OR OWNER'S REPRESENTATIVE		DATE 9-30-21	

DISTRIBUTION: WHITE - WATER UTILITIES; YELLOW - OWNER OR TESTER