## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRSUBD20202008

Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Sanitary Sewer - Mandrel Ronald Paynter Passed Wednesday, October

27, 2021

Informational:

1 Misc 9-24-21 11:00 AN. Began Mandrel test at 9:30 and stoped at 11:00 because

contractors poured the concrete inverts wrong not allowing the mandrel to enter the 8" pipe. Inverts need to be fixed. Andrew is going to call and

reschedule.

**Comments:**