

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20210775
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Stabilized Subgrade	Ronald Paynter	Partial	Wednesday, October 27, 2021

Informational:	
1 Misc	Laid down portland cement dust, tilled in 8" into subgrade then bladed and rolled mixture into subgrade. KC testing was onsite doing compaction testing. 10/26 ES

Comments: