

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211323
Address: 3130 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Not Ready	Thursday, October 28, 2021

Corrective Action Required:

1 Misc

INSPECTION DENIED

-ADDRESS EROSION CONTROL ON LOT. MAINTAIN SILT FENCE ON LOT

-ADDRESS COVERED PATIO PIERS THAT HAVE BEEN POURED WITHOUT REINSPECTION,

SEE FAILED PIER INSPECTION REPORT FROM 9/13/21, (2) 24" WIDE PIERS AT COVERED PATIO PER APPROVED PLANS

Comments: