

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215626
Address: 1304 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Friday, October 29, 2021

Corrective Action Required:

1	Misc	-Reroute gas csst line min 3" away from framing surface. Re-test the gas line -Bath fan flex duct cannot exceed 14 ft -Provide clean out for the 3" waste stack near wet bar -Shower trap cannot be a s-trap
---	------	---

****OK TO INSULATE**

Comments: