

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20210095  
Address: 4409 SW TANZANITE CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Friday, October 29, 2021

Corrective Action Required:

1	Misc	-Complete final grade and sod -splash blocks and sump pump discharge 36" from foundation -seal top of lights at house front, right and left of garage -guard rail as required at front stoop -to much trash in garage to inspect inside garage -adjust self closing door at garage -spark ring required above fire place -broken window at north wall stairs -hole in wall at south wall above outlet exposing back of adjacent wall junction box -sheer off set screw for anti-siphon device -deck guard rail spacing must not be more that 4" -seal top of A/c disconnect & meter can -check meter at time of final grade
---	------	---

**Comments:**