CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210427

Address: 250 NW MCNARY CT, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Fire Line - Hydrostatic Test Joe Starlin Passed Friday, October 29,

2021

Informational:

1 Misc 10/29/21 Friday (Bair Const Don's crew)

2 hour fire line hydrostatic test with Backflow preventer to the inside of building. Test passed inspection, bleed line of air pressure from hydrant to

check line pressure actually existence.

Comments: