

1. FIRE EXTINGUISHERS (FE ON PLAN) ARE LIGHT HAZARD AND PLACED IN AREAS ACCESSIBLE TO OCCUPANTS. CONFIRM LOCATIONS WITH FIRE MARSHAL PRIOR TO INSTALL. SHALL SUPPLY AND INSTALL 2A.C. FIRE EXTINGUISHERS. COVERAGE PER EACH EXTINGUISHER SHALL NOT EXCEED 15' DIAMETER. PROTECT AGAINST ADJACENT SPACE SHALL HAVE LEFT (S) FIRE EXTINGUISHERS, ONE SHALL BE IN THE SALES AREA, ONE SHALL BE IN THE CASH REGISTER AREA AND ONE SHALL BE IN THE WORKROOM AREA. EXTINGUISHERS MUST BE WALL MOUNTED, IN PLAIN VIEW, AND BE AT LEAST 18" FROM THE FLOOR BUT NO HIGHER THAN 40" FROM THE FLOOR TO THE TOP OF THE EXTINGUISHER.
2. REFER TO SHEET A5.0 FOR TACTILE SIGNS SHOWN ON LIFE SAFETY PLAN.



design and construction documents as instruments of service are given in confidence and remain the property of Onyx Creative. The use of this design and these construction documents for purposes other than the specific project named herein is strictly prohibited without expressed written consent of Onyx Creative.

petpeople
SUMMIT AT WEST PRYOR
940 NW PRYOR RD, UNIT J
LEE'S SUMMIT (KANSAS CITY), MO

Project No.:	18894
Drawn By:	XXX
Date	Issue
1/18/2021	Bid/ Permit
4/27/2021	2 Revision 2
1/22/2021	3 Revision 3

A6.0

TEXTURE/ LIFE SAFETY PLAN

onyx | creative
25001 Emery Road, Suite 400
Cleveland, Ohio 44128
216.223.3200 onyxcreative.com

10.21.21

Job Path: \\Master\HA STANDARDS\CAD STANDARDS\TEMPLATE\Master Template.dwt
Drawn By: C E Mierke