

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211323
Address: 3130 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Patrick Schonfeldt	Failed	Monday, November 01, 2021

Corrective Action Required:

1	Misc	-SEE ELECTRICAL SERVICE INSPECTION FOR CORRECTIONS AT UFER BEFORE RELEASE OF GAS SERVICE -GAS PRESSURE OK
---	------	---

Comments: