

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211323
Address: 3130 SW BLUE RIBBON ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Patrick Schonfeldt	Failed	Monday, November 01, 2021

Corrective Action Required:

1	Misc	-Complete electrical at service panel -Tighten panel bonding screw -Not approved use of ground clamps to connect multiple pieces of rebar at UFER, UFER needs to remain accessible at finish
---	------	--

Comments: