

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211510
Address: 2362 SW OLD PORT RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Monday, November 01, 2021

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- correct erosion control and silt fence.- nail sheeting to bottom plate west side- - Block out seam above front door- Address foundation crack under I beam in basement , engineers letter- Wall space at stairs outlet do not meet requirements- Notched timber at stairs-nail off sheeting west side bedroom 2-fire block penetration second floor chase near 2 bedroom-missing nails hanger master bedroom-fire block penetration laundry room- fire block dead space by garage and ductwork- need boca plate on waste 3" in stairs 2" above sole plate-nail joist hangers in basement near furnace- tighten anchor bolts on metal post in basement
---	------	--

Comments: