

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204561
Address: 211 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, November 02, 2021

Corrective Action Required:

1	Miscellaneous Correction	-Solid block and nail sheathing /-Bottom plate to be same size minimum of studs at garage/ bath /-Connect bath exhaust fans -/Seal upward penetrations at elevator -(2) 1/2" through bolts at all post to beam connections Install missing windows
---	--------------------------	---

Comments: