

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRSUBD20202008  
Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Site Visit</b>	Ronald Paynter	Partial	Tuesday, November 02, 2021

Informational: 1 Misc	ESS was on site today to start mass stripping the area. RP 5-25-21
Informational: 2 Misc	ESS still prepping the job site. Blasters have started drilling to blast out the rock shelf's. RP 6-4-21
Informational: 3 Misc	ESS still prepping the job site. Blasters have started drilling to blast out the rock shelf's. RP 6-4-21
Informational: 4 Misc	ESS still prepping the job site. Blasters have started drilling to blast out the rock shelf's. RP 6-4-21
Informational: 5 Misc	EDS blasted the the area around Killarney. They have also started drilling the O'Brien / Patch area. RP 6-8-21
Informational: 6 Misc	EDS finished blasting along Patch and O'Brien. ESS has 2 crews laying sanitary pipe and 1 crew breaking up the large rocks. RP 7-12-21
Informational: 7 Misc	No work going on today due to the rain overnight.
Informational: 8 Misc	ESS is cutting roadways down to grade. RP 10-1-21
Informational:	

9

Misc

Water had an issue with MH 28450 having too many risers. Found out the barrel section was a flat top versus a cone. Water came back out and approved the risers and manhole. RP 11-2-21

**Comments:**