

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20191614
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Failed	Tuesday, November 02, 2021

Informational:
1 THIRD FLOOR —AREAS APPROVED—

BUILDING C
COMPLETE

BUILDING B
COMPLETE

BUILDING A
-COMPLETE EXCEPT ELEVATOR

Informational:
2 SECOND FLOOR —AREAS APPROVED—

BUILDING C
COMPLETE

BUILDING B
COMPLETE

BUILDING A
COMPLETE EXCEPT ELEVATOR

Informational:

3 FIRST FLOOR

—AREAS APPROVED—

BUILDING C
COMPLETE

BUILDING B
COMPLETE

BUILDING A
COMPLETE

MCAL BUILDING
Kitchen 164 OK-CEILING OK FOR ROCK NOT AT HOODS
CORRIDOR 167 TO 10' FROM SHAFT WALL
CORRIDOR 169,172,176,177a,177, 173, 34,39,42,48
MC UNITS 1-18, 21,24-33, 36,37,44,45,46
SHARED SPACES: 149,150,152,153,154,156,157,159,161,162, 162A,174,174A,175
AL UNITS: 102-147

Corrective Action Required:

4 Miscellaneous
Correction

Kitchen area:
-Strap DWV, Seal penetrations, Complete plumbing and sprinkler above
ceiling

Comments: