

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211236  
Address: 2163 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Not Ready	Tuesday, November 02, 2021

Corrective Action Required:

1	Miscellaneous Correction	-Address single car bay to attached at top plates at return -Complete gas and fireplace installation and secure counter strike gas line & provide shield at entry to fireplace, connect gas line at fireplace and provide minimum 10 PSI 15 minutes  -Repair damaged sheathing at sec ( service entry cable above service panel still damaged 11/2/21) -no pressure at gas gauge ( still 0 PSI 11/2/21
---	--------------------------	---

**Comments:**