

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204450  
Address: 2013 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Michael Harkins	Not Ready	Tuesday, November 02, 2021

Corrective Action Required:

1	Misc	Sidewalk inspection pending Remove dust covers smoke detectors Provide back-flow device at water shut off ( anti siphon device still missing ) 7 3/4 max riser at bottom of deck stairs  DO NOT MOVE FURNITURE INTO A HOUSE WITHOUT OCCUPANCY INSPECTION / TCO
---	------	---

**Comments:**