

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20202008
Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	Ronald Paynter	Passed	Tuesday, November 02, 2021

Informational:
1 Misc Proof roll passed except for one 10ft. Area by O'Brien. Installed a stretch of geo grid and added 6 " of type 5 rock. Trucks ran over it this morning and it was good to go , This proof roll was for chemical subgrade, will still need one for the rock.

Informational:
2 Misc They had a tandem dump truck with a 21.3 ton load. Proof rolled just the curb line. Everything passed except for 2 storm boxes on O'Brien. They will make adjustments and reroll this area next week. RP 10-18-21

Informational:
3 Misc They had a tandem dump truck with a 19.2 ton load. The base was solid, no deflection was noticed during the test. RP 11-2-21

Comments: