

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20214264
Address: 4816 NE FREEHOLD CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - R	Khanh Nguyen	Failed	Tuesday, November 02, 2021

Corrective Action Required:

1	Misc	-PROVIDE A SLEEVE AT SEWER PENETRATION OF FOUNDATION WALL -PROVIDE GRAVEL SUPPORT FOR SEWER
---	------	--

Comments: