

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20213120

Address: 1041 NE SAM WALTON LN, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Michael Harkins	Failed	Wednesday, November 03, 2021

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	- (7) CAN LIGHTS IN SOFFIT AT ORDER & SEATING AREA -
---	----------------------------------	--

Corrective Action Required:

2	Miscellaneous Correction	- FIRE CAULK PENETRATIONS ABOVE POS FIRE CAULK ABANDON DATA - - CONDUIT PENETRATION SOUTH WALL AND SEAL CONDUIT -
---	--------------------------	---

Comments: