

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20211583  
Address: 1705 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Wednesday, November 03, 2021

Informational:

1	Misc	GARAGE PORTAL EXTERIOR OK TO COVER
---	------	------------------------------------

Corrective Action Required:

2	Misc	-rafter ties bottom third of rafters rear covered patio, discussed correction with framer on site
---	------	---

**\*\*OK TO INSULATE AND ROCK\*\***

**Comments:**