



November 2, 2021

Summit Homes  
120 SE 30<sup>th</sup> St.  
Lee's Summit, MO 64082

**RE: Field Issue of OSB installation for engineered braced wall panel method for Lot #102 Reserve at Stoney Creek – 1705 SW Hightown Dr. Lee's Summit, MO 64082 – Permit # PRRES20211583**

This letter addresses the OSB installation for engineered bracing method in the great room for Lot# 102 Reserve at Stoney Creek.

- It is structurally acceptable to install 15/32" thick OSB on engineered braced wall panels at great room portal frame on interior.
- It is structurally acceptable to omit installing OSB over rim board.
- Install 8d nails at 6" for panel edges and 12" for field nailing pattern and blocking per plan.

Sincerely,

A handwritten signature in blue ink, appearing to read "B. Huxol", is written over a light blue horizontal line.

Bradley Huxol, PE

