

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212322  
Address: 2906 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                 | Inspector:         | Outcome: | Date:                           |
|---------------------------------------------|--------------------|----------|---------------------------------|
| <b>Gas Service Inspection - Residential</b> | Patrick Schonfeldt | Failed   | Wednesday,<br>November 03, 2021 |

Corrective Action Required:

|   |      |                                                       |
|---|------|-------------------------------------------------------|
| 1 | Misc | -Gas pressure at 0 psi, must maintain 10 psi for test |
|---|------|-------------------------------------------------------|

**Comments:**