

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210625
Address: 2110 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Michael Harkins	Failed	Wednesday, November 03, 2021

Corrective Action Required:

1	Miscellaneous Correction	IDENTIFY UFER GROUND AR SERVICE PANEL (GREEN TAPE)
---	--------------------------	--

Comments: