

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203582
Address: 2312 SW CHASE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, November 03, 2021

Corrective Action Required:

1	Misc	-complete sod/landscaping -Handrail required at front stoop -GFCI protection required for dishwasher -dinnette outlets need arc fault protection(sub panel) -Tamper resistance caps required at A/c compressor -A/c whip secured above grade -final sidewalk inspection required
---	------	--

Comments: