CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20204861Address:334 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, November 04, 2021

Corrective Action Required:

- 1
 Misc
 -seal top of front lights at siding, top of A/c disconnect & meter can

 -sod & final grade
 - provide splash blocks and sump pump extension 36" from foundation
 - -guard rail required at front stoop where more than 30 $^{\prime\prime}$ from grade
 - -Self closing door at garage
 - -provide bonding for Csst gas line per code

Comments: