

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210399
Address: 4524 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, November 04, 2021

Corrective Action Required:

1	Misc	11/4/21 - BELOW CORRECTIONS CARRIED FROM ALL ROUGH -ANCHOR ALL SCH 40 STEEL COLUMNS TO FLOOR AT BASEMENT -AC ELECTRICAL DISCONNECT NOT INSTALLED AT ROUGH, CONFIRM ELECTRICAL AND RECEPTACLE WITHIN 25' AT OCCUPANCY
---	------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: