

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215650
Address: 2038 SW FARM FIELD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Patrick Schonfeldt	Not Ready	Thursday, November 04, 2021

Corrective Action Required:

1	Misc	INSPECTION DENIED
---	------	-------------------

NO EROSION CONTROL PRESENT AT TIME OF INSPECTION 11:28 AM, EROSION CONTROL REQUIRED AT PERIMETER OF LOT, GRAVEL FILTER REQUIRED

Comments: