

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20215650  
Address: 2038 SW FARM FIELD LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Patrick Schonfeldt	Failed	Thursday, November 04, 2021

Corrective Action Required:

1	Misc	INSPECTION DENIED
---	------	-------------------

NO EROSION CONTROL PRESENT AT TIME OF INSPECTION 11:28 AM, EROSION CONTROL REQUIRED AT PERIMETER OF LOT, GRAVEL FILTER REQUIRED

**Comments:**