

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210880  
Address: 2118 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Not Ready	Thursday, November 04, 2021

Corrective Action Required:

1	Miscellaneous Correction	Fire block dead space & chase dining room Fire block furr outs garage Furr out HVAC for insulation garage Address double floor joist cut near radon basement ( CUT A DOUBLE REPLACED WITH SINGLE ) Fire block soffit near patio door Address bores in LVL above refrigerator ( DON'T SEE ENGINEER'S LETTER UPLOADED) Fire block chase in pantry FIRE BLOCK GAP AT BASEMENT SCH 40 columns garage beam Replace LIB rear garage wall Fire block DWV bath 5 Seal bad bore floor at tub Trap bath 2
---	--------------------------	---

Comments: