

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213762
Address: 2924 NW THOREAU DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Michael Harkins	Failed	Friday, November 05, 2021

Corrective Action Required:
1 Misc 10/27/21 - INSPECTION DENIED, NO ACCESS
PROVIDE ACESS FOR INSPECTION, LADDERS BOTH SIDES OF WALLS TO BE ABLE TO INSPECT

Corrective Action Required:
2 Misc bonding shall conform to contour of the pool uniformly spaced

Comments: