

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211034
Address: 318 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Friday, November 05, 2021

Corrective Action Required:

1	Miscellaneous Correction	Furr out HVAC ducts garage to allow for insulation (needs fire blocking) Seal upward penetration for dwv at house/garage wall Provide 4 stud pack at GT bearing point bedroom 2 per plan(in wrong location) Solid block & nail sheathing breaks south of front door Fire block HVAC chase at stairway Fire block HVAC chase near patio door Seal HVAC chase
---	--------------------------	---

Comments: