

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20191614  
Address: 1701 SE OLDHAM PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Partial	Friday, November 05, 2021

Informational:	
1      THIRD FLOOR	— AREAS APPROVED —
	***BUILDING C*** COMPLETE
	***BUILDING B*** COMPLETE
	***BUILDING A*** -COMPLETE EXCEPT ELEVATOR

Informational:	
2      SECOND FLOOR	— AREAS APPROVED —
	***BUILDING C*** COMPLETE
	***BUILDING B*** COMPLETE
	***BUILDING A*** COMPLETE EXCEPT ELEVATOR

Informational:

3 FIRST FLOOR

—AREAS APPROVED—

\*\*\*BUILDING C\*\*\*  
COMPLETE

\*\*\*BUILDING B\*\*\*  
COMPLETE

\*\*\*BUILDING A\*\*\*  
COMPLETE

\*\*MCAL BUILDING\*\*

Kitchen 164 OK-CEILING OK FOR ROCK NOT AT HOODS

CORRIDOR 167 TO 10' FROM SHAFT WALL

CORRIDOR 169,172,176,177a,177, 173, 34,39,42,48

MC UNITS 1-18, 21,24-33, 36,37,44,45,46

SHARED SPACES: 149,150,152,153,154,156,157,159,161,162, 162A,174,174A,175

AL UNITS: 102-147

164 walls ok except at column

Corrective Action Required:

4 Miscellaneous  
Correction

KITCHEN AREA, Complete plumbing and sprinkler above ceiling

Comments: