

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20202008  
Address: 2030 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Surface</b>	Ronald Paynter	Partial	Saturday, November 06, 2021

Informational:	
1 Misc	Seal-O-Matic laid 1,459 tons of APWA Type 5 R for base on O'Brien, Patch and Killarney. KC Testing was on site doing compaction testing. RP 11-3-21
Informational:	
2 Misc	Seal-O-Matic laid down 825 tons of APWA Type 5 V asphalt for the roadway surface. KC Testing was on site doing compaction testing. We rejected 1 truck load based on the appearance of the material. RP 11-6-21

**Comments:**