

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210348
Address: 2930 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, October 26, 2021

Corrective Action Required:

1	Misc	*PAY ALL FEES* -Driveway and sidewalk inspection need complete -Obtain sprinkler permit -outlet above fireplace need complete -GFCI required for dishwasher -label non GFCI outlet in all unfinished spaces -open/incomplete electrical junction box at back basement wall -complete secondary locking device on basement back sliding door -siding must be 6" from grade -provide splash blocks and sump pump discharge 36" from foundation -uncover MH Lid
---	------	--

Comments: