

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212025
Address: 1808 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, November 02, 2021

Informational:

1	Misc	*8-25-21 Portal framing exterior ok to cover
---	------	---

Corrective Action Required:

2	Misc	Provide boca plate wet bar at soffit Provide anchor bolt end of plate t corner near sub panel Seal fire blocking north wall bed #4 Provide anchor bolt end of plate near patio door Fire block short wall in bed 3 closet Seal penetrations bed 3 bath at soffit Provide boca plate at soffit outside bed 3 bath Provide nails joist hanger great room near arch to master Seal upward penetrations fireplace on deck Address gluelams used in place of LVLs Address missing double rafters above stairway at entry
---	------	---

Comments: