

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204747  
Address: 4406 SW AMETHYST DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Wednesday, October 27, 2021

Corrective Action Required:

3	Misc	-security screws at front door hinges/missing screws -splash blocks for down spouts and sump pump extension 36" from foundation -seal top of meter can, A/c disconnect, & all other exterior penetrations -anti tip device on oven -label all non GFCI outlets in unfinished spaces -all outlets in garage space not currently working -smoke/carbon dioxide detectors not all ran together -guard rail at front stoop as required by section R312.1.1
---	------	---

Comments: