

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20214153

Address: 2150 NW LOWENSTEIN DR, LEES SUMMIT, MO 640812100 NW LOWENSTEIN DR, LEES SUMMIT, MO
64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water - Material Verification	Ronald Paynter	Partial	Tuesday, November 09, 2021

Informational:

1 Misc

Water materials onsite: 6", 8" and 12" C900 pipe, 6" and 8" gate valves, multiple fittings and bend connections and gaskets. Did notice some adapters were wrong, not epoxy coated, they are going to get these replaced through manufacturer. Still waiting to verify 12" butterfly valves, or fire hydrants.

Comments: